

ZAŁĄCZNIK 2

Zestawienie obliczeniowych strat ciepła dla pomieszczeń.

Numer pomieszczenia/ wewnętrzna temperatura obliczeniowa (st.C)	Obliczeniowe straty ciepła (W)
P.21/ 20,0 °C	2855
P.22/ 20,0 °C	2751
P.23/ 20,0 °C	996
P.24/ 20,0 °C	2271
P.25/ 20,0 °C	2407
P.26/ 20,0 °C	1176
P.27/ 24,0 °C	3126
P.28/ 24,0 °C	2808
P.31+P.32/ 24,0 °C	495
P.33/ 16,0 °C	1670
P.34/ 12,0 °C	489
P.35/ 12,0 °C	408
P.37/ 12,0 °C	506
P.38/ 20,0 °C	2286
P.39/ 20,0 °C	2097
P.40/ 24,0 °C	1107
P.41/ 24,0 °C	2936
P.43/ 24,0 °C	4040
P.44/ 24,0 °C	116
P.45/ 24,0 °C	1016

P.46+P.47/ 24,0 °C	1296
P.48/ 16,0 °C	646
P.49/ 12,0 °C	516
0.100/ 20,0 °C	1272
0.101/ 24,0 °C	1439
0.102/ 20,0 °C	988
0.104/ 20,0 °C	820
0.105+0.106/ 20,0 °C	113
0.107+0.109/ 20,0 °C	25
0.108+0.110/ 20,0 °C	27
0.112/ 20,0 °C	213
0.113/ 20,0 °C	1025
0.114/ 24,0 °C	1491
0.115/ 20,0 °C	6
0.117/ 20,0 °C	76
0.118/ 20,0 °C	1491
0.60a/ 20,0 °C	1796
0.60b/ 20,0 °C	2570
0.61/ 20,0 °C	948
0.62/ 24,0 °C	1632
0.63/ 20,0 °C	677
0.64/ 24,0 °C	1660
0.65/ 20,0 °C	608
0.66+0.67/ 20,0 °C	55

0.68+0.69/ 20,0 °C	75
0.70a/ 20,0 °C	1185
0.70b/ 20,0 °C	1174
0.71/ 24,0 °C	1211
0.72/ 24,0 °C	1144
0.75/ 24,0 °C	1708
0.74/ 24,0 °C	1342
0.73/ 20,0 °C	641
0.77/ 24,0 °C	2787
0.78/ 24,0 °C	1144
0.79/ 20,0 °C	73
0.80/ 20,0 °C	81
0.81/ 20,0 °C	678
0.85/ 20,0 °C	39
0.86/ 20,0 °C	655
0.89/ 24,0 °C	212
0.91/ 24,0 °C	269
0.92/ 24,0 °C	2026
0.93/ 20,0 °C	2002
0.95/ 20,0 °C	1371
0.96/ 24,0 °C	1534
0.97/ 24,0 °C	1369
0.98/ 24,0 °C	1102
0.99/ 24,0 °C	1375
1.100/ 20,0 °C	52

1.101/ 24,0 °C	994
1.102/ 20,0 °C	42
1.104/ 24,0 °C	2294
1.105/ 24,0 °C	5324
1.106/ 20,0 °C	1453
1.107/ 24,0 °C	1578
1.108/ 24,0 °C	795
1.56/ 20,0 °C	1252
1.58/ 20,0 °C	855
1.59/ 24,0 °C	1795
1.60/ 20,0 °C	2205
1.61/ 20,0 °C	110
1.62/ 20,0 °C	916
1.66/ 20,0 °C	69
1.67/ 20,0 °C	808
1.70/ 24,0 °C	1646
1.71/ 24,0 °C	1528
1.72/ 24,0 °C	1304
1.73/ 24,0 °C	3099
1.74/ 20,0 °C	2007
1.75/ 20,0 °C	3344
1.76/ 20,0 °C	813
1.79/ 20,0 °C	2687
1.80/ 20,0 °C	1208
1.81/ 20,0 °C	545

1.82/ 20,0 °C	883
1.83/ 20,0 °C	1411
1.85/ 20,0 °C	94
1.86/ 20,0 °C	302
1.87/ 20,0 °C	813
1.88/ 20,0 °C	1176
1.89/ 20,0 °C	898
1.90/ 20,0 °C	147
1.91/ 20,0 °C	1161
1.93/ 20,0 °C	1905
1.94+1.95/ 20,0 °C	115
1.96/ 20,0 °C	173
1.99/ 24,0 °C	1217